

# Display energy certificate (DEC)

Hyde Leisure Pool Walker Lane HYDE SK14 5PL	Operational rating <b>C</b>	Certificate number: 0944-0210-5149-0538-8070
		Valid until: 27 April 2022
		Total useful floor area: 2843 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>		
51-75	<b>C</b>	<b>51   C</b>	
76-100	<b>D</b>		
			100
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	166	610
Typical energy use (kWh/m <sup>2</sup> /year)	311	1233
Energy from renewables	0%	0%

## Previous operational ratings

Date	Operational rating
April 2021	<b>51   C</b>
April 2020	<b>60   C</b>
April 2019	<b>57   C</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
April 2021	260	336	N/A
April 2020	358	370	N/A
April 2019	387	295	N/A

## Assessment details

Assessor's name	Stephen Ashton
Accreditation scheme	CIBSE Certification Limited
Employer/Trading name	Digital Energy Ltd.
Employer/Trading address	Unit 10 Enterprise House, Manchester Science Park, Manchester, M15 6SE
Issue date	16 April 2021
Nominated date	28 April 2021
Assessor's declaration	Not related to the occupier.